

ELEVATED SURFACES

- ☐ Are signs posted, when appropriate, showing the elevated surface load capacity?

Action to be Taken

Assigned To:

- ☐ Are work surfaces elevated more than 4 feet above the floor or ground provided with standard guardrails (6 feet for construction work)?

Action to be Taken

Assigned To:

- ☐ Are all elevated surfaces (beneath which people or machinery could be exposed to falling objects) provided with standard toeboards?

Action to be Taken

Assigned To:

- ☐ Are approved means of access and egress provided to elevated storage and work surfaces?

Action to be Taken

Assigned To:

- ☐ Is required headroom provided where necessary?

Action to be Taken

Assigned To:

- ☐ Is material on elevated surfaces piled, stacked or racked in a manner to prevent it from tipping, falling, collapsing, rolling or spreading?

Action to be Taken

Assigned To:

- ☐ Are dock boards or bridge plates used when transferring materials between docks and trucks or rail cars?

Action to be Taken

Assigned To:
